



cfo@vmc.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOVMC/2021/00013202

Date: 02/04/2025

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOVMC/2021/00013202/R1

Building Occupancy/Category: Educational (non-residential)

To,

DELHI PUBLIC SCHOOL HARNI

DELHI PUBLIC SCHOOL CBSC HARNI VIROD ROAD NR MOTNATH MANDIR VADODARA Vadodara MC 390022

Fire Region: Vadodara MC

Mobile No: 9925758788 Email ID: info@dpsharni.com

This has reference to your Application No. 2025/00106884 dated 29/01/2025 for Fire Safety Certificate Renewal (FSCR) for the building/premise DELHI PUBLIC SCHOOL CBSC (name of the Building/ Project), as per below mentioned details:

1. TP Number: 2
2. FP Number: 3 5 6 7
3. Survey Number: 160 161 163 168 169 177/1 2
4. Village Name: VADODARA
5. Name of Block(s): DELHI PUBLIC SCHOOL CBSC

The building/premise was inspected on 02/04/2025 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 02/04/2025
2. Six monthly inspection was done on 02/04/2025

The Fire Safety Certificate is renewed for a period of two (2) years upto 02/04/2027 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Kantibhai Ashikbhai Patel
Fire Safety Officer - Advance (FSO-A)
2021/000232

Date: 02/04/2025
Time: 11:29 AM



FSCA/O/CFOVMC/2021/00013202/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.